

PFAS Sampling at Non-DoD Supplied Water Systems within the NSE AOR

Installation	Water Supplier	Sample Location	Sample Date	FY22 Results (ppt)			Notes
				PFOS	PFOA	PFOS + PFOA	
Naval Station Everett	City of Everett PWD	Bldg. 1950	10-Nov-21	Not Detected	Not Detected	N/A	PFAS compounds not detected. Meets DoD policy and WA State Action Level requirements.
		Bldg. 2106	10-Nov-21	Not Detected	Not Detected	N/A	PFAS compounds not detected. Meets DoD policy and WA State Action Level requirements.
Smokey Point	Marysville Utilities	Bldg. 13906	10-Nov-21	Not Detected	Not Detected	N/A	PFAS compounds not detected. Meets DoD policy and WA State Action Level requirements.
		Bldg. 13912	10-Nov-21	Not Detected	Not Detected	N/A	PFAS compounds not detected. Meets DoD policy and WA State Action Level requirements.
Pacific Beach	Grays Harbor Dept. of Public Service District	Bldg. 146	14-Dec-21	Not Detected	Not Detected	N/A	PFAS compounds not detected. Meets DoD policy and WA State Action Level requirements.
NOSC Portland	Portland Water Bureau	Bldg. 1	15-Dec-21	Not Detected	Not Detected	N/A	PFAS compounds not detected. Meets DoD policy and WA State Action Level requirements.
NOSC Spokane	City of Spokane	Bldg. 1	14-Dec-21	0.968J	Not Detected	0.968J	PFAS compounds detected, but below LHA and WA State Action Levels. Meets DoD policy and WA State requirements. The "J" qualifier indicates that the results were below the reporting limit.
Bayview, ID	Bayview Water & Sewer Dist.	Bldg. 200	15-Dec-21	Not Detected	Not Detected	N/A	PFAS compounds not detected. Meets DoD policy and WA State Action Level requirements.
LaMoure, ND	Southeast Water User District	Bldg. 01	15-Dec-21	Not Detected	Not Detected	N/A	PFAS compounds not detected. Meets DoD policy and WA State Action Level requirements.
Sioux Falls	City of Sioux Fall	Sampling Not Required	Policy req. met				2019 – PFOS and PFOA not detected during water supplier sampling.
NOSC Des Moines	Des Moines Waterworks	Sampling Not Required	Policy req. met				2019 – PFOS and PFOA not detected during water supplier sampling.
NOSC Minneapolis	City of Minneapolis	Sampling Not Required	Policy req. met				2018 – PFOS and PFOA not detected during water supplier sampling.