

**2019**  
**Annual Consumer Confidence Report on the Quality of**  
**Jackson Park/Naval Hospital Bremerton Drinking Water**

*This is an annual report on the quality of water delivered by the drinking water system at Naval Base Kitsap Jackson Park and Naval Hospital Bremerton. Presented in this report is information on the source of our water, its constituents, and the health risks associated with any contaminants. Please read on for a full explanation of the quality of our water.*

***Our water is safe to drink.***

## **Source of our Water**

Jackson Park and Naval Hospital Bremerton (JP/NAVHOSP) purchases drinking water from the City of Bremerton. Bremerton's water sources consist of surface water from the Union River Reservoir and groundwater from production wells located in Kitsap County. All sources are managed per Washington State Department of Health (WDOH) requirements, Environmental Protection Agency (EPA) regulations, and best management practices for water supply systems. Bremerton owns and protects the 3,000 acre watershed surrounding the Union River supply. Access to the watershed is secured, patrolled, and limited to water supply and forestry management activities. Groundwater wells are also safeguarded through their wellhead protection efforts. Further information about the City of Bremerton's water system is included in the attached Drinking Water Quality report 2019. Additional information can be found at their website at <https://www.bremertonwa.gov/282/Drinking-Water-Quality-Report>.

Both the JP/NAVHOSP and City of Bremerton's water systems are operated and maintained by experienced personnel licensed by the state of Washington. The WDOH determined the City of Bremerton's water sources was of such good quality the city was not required to install filtration as long as all water quality, operational, and watershed protection requirements were met. The City of Bremerton consistently meets these quality standards. Treatment of Bremerton's water currently consists of ultraviolet light and chlorine for disinfection and adjustment to increase pH to reduce corrosion of lead and copper from customer plumbing. Corrosion control has been in place since 1999.

## **Information from EPA**

The sources of drinking water include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land and through the ground, it dissolves naturally occurring minerals, and in some cases, radioactive material. It can also pick up substances resulting from the presence of animals or from human activity. These substances are referred to as contaminants by the EPA.

Contaminants that may be present in source water include:

- a. Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife;
- b. Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming;
- c. Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses;
- d. Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems;
- e. Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the EPA and the WDOH prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) and Washington State Department of Agriculture (WDOA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at 800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**2019**  
**Annual Consumer Confidence Report on the Quality of**  
**Jackson Park/Naval Hospital Bremerton Drinking Water**

**Household Cross Connection Protection**

A cross connection happens when your drinking water plumbing is connected or in contact with a non-drinking water system such as a lawn sprayer, soap dispenser, sprinkler system, swimming pool, irrigation system, or water heating and cooling system. When water flows back from the non-drinking water system into your drinking water plumbing system, your drinking water becomes contaminated. Signs of contamination include discolored water and unusual smells. See attached pamphlet titled *Help Protect Your Drinking Water from Contamination* for more information on how to protect your drinking water from cross connections.

**Additional Information for Lead**

In Washington State, lead in drinking water comes primarily from materials and components used in household plumbing. The more time water has been sitting in pipes, the more dissolved metals, such as lead, it may contain. Elevated levels of lead can cause serious health problems, especially in pregnant women and young children.

To help reduce potential exposure to lead: for any drinking water tap that has not been used for 6 hours or more, flush water through the tap for thirty seconds to two minutes, or until the water is noticeably colder, before using for drinking or cooking. You can use the flushed water for watering plants, washing dishes, or general cleaning. Only use water from the cold-water tap for drinking, cooking, and especially for making baby formula. Hot water is likely to contain higher levels of lead. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water is available from EPA's Safe Drinking Water Hotline at 1-800-426-4791 or online at <http://www.epa.gov/safewater/lead>.

Compliance (Action Level) for lead and copper samples is based on a 90th percentile. This means that the concentration of lead and copper must be less than or equal to the action level in at least 90% of the samples collected. In other words, out of every 10 locations sampled, 9 were at or below the Action Level.

**Water Quality Summary**

The Navy has water testing requirements in addition to the City of Bremerton's water quality program. The below information provides a summary of the water testing conducted by the Navy. Our water system uses only EPA approved laboratory methods to analyze drinking water. Samples are drawn from designated sample sites in the distribution system by licensed water shop personnel. All samples are then transported to an accredited laboratory where a full spectrum of water quality analyses are performed for the parameters listed below.

Sampling Schedule	
Parameter	Frequency
Coliform Monitoring <sup>1</sup>	Monthly
Chlorine Residual	Daily <sup>2</sup>
Lead and Copper	Every 3 years
Total Trihalomethane (THM)	Quarterly
Halo-Acetic Acids (HAA5)	Quarterly
Asbestos	Every 9 years

<sup>1</sup> Contaminants in this group include total coliform.

<sup>2</sup> Samples taken on weekdays only.

**Detected Contaminants**

In order to ensure that tap water is safe to drink, EPA and WDOH prescribe regulations which limit the amount of contaminants in water provided by public water systems. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the 2019 calendar year. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of the data, though representative, may be more than one year old.

**2019**  
**Annual Consumer Confidence Report on the Quality of**  
**Jackson Park/Naval Hospital Bremerton Drinking Water**

The City of Bremerton tests for over 50 inorganic and organic compounds in the source water. Compounds detected in the City of Bremerton's source water during 2019 met all the protective standards set by federal and state agencies. Please refer to the attached City of Bremerton Drinking Water Quality report for 2019 for complete test results.

Due to being a consecutive system, meaning we purchase our water from the City of Bremerton, there are only a few water quality parameters that are tested for in our water system within the fence line of the base. The tables below list the drinking water contaminants that we detected by water testing performed on the JP/NAVHOSP water system within the fence line of the base. Please refer to the tables below and the attached City of Bremerton Drinking Water Quality report for 2018 for complete test results. Although many more contaminants were tested, only those substances listed below were found in your water. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminates	MCLG	AL	Your Water (90 <sup>th</sup> %)	Sample Date	# of Samples Exceeding AL	Violation	Typical Sources
<b>Inorganic Contaminates</b>							
Lead (ppb)	0	15	1 <sup>1</sup>	2018	0	No	Corrosion of household plumbing systems; erosion of natural deposits.
Copper (ppm)	0	1.3	0.04 <sup>1</sup>	2018	0	No	Corrosion of household plumbing systems; erosion of natural deposits.

<sup>1</sup> This is the 90th % value from the most recent testing which is below the AL, demonstrating our system is in compliance with the Lead & Copper Rule.

Contaminates	MCLG	MCL	Your Water	Range		Sample Date	Violation	Typical Sources
				Low	High			
<b>Volatile Organic Contaminants</b>								
Haloacetic Acids (HAA) (ppb)	N/A	60	22.1 <sup>1</sup>	9.2	29	2019	No	By-product of drinking water disinfection
Total Trihalomethane (TTHM) (ppb)	N/A	80	61.8 <sup>1</sup>	44	69	2019	No	By-product of drinking water disinfection
<b>Asbestos</b>								
Asbestos (Million Fibers/L) <sup>2</sup>	0	7	ND	ND	ND	2016	No	Corrosion of plumbing systems

<sup>1</sup> LRAA for the 2019 calendar year

<sup>2</sup> Fibers longer 10 µm

**2019**  
**Annual Consumer Confidence Report on the Quality of  
Jackson Park/Naval Hospital Bremerton Drinking Water**

**Definitions and Abbreviations**

**AL** (Action Level) – The concentration of a contaminant, which, if exceeded, triggers treatment techniques or other requirements, which must be followed.

**Level Detected** – Laboratory analytical result for a contaminant; this value is evaluated against an MCL or AL to determine compliance.

**LRAA** – Locational Running Annual Average

**MCL** (Maximum Contaminant Level) – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. Under the Safe Drinking Water Act, the EPA establishes these MCLs for compliance purposes.

**MCLG** (Maximum Contaminant Level Goal) – The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**N/A** – Not Applicable

**ND** – Not Detected. The compound was not detected above the Lab's Method Detection Limit

**pCi/l** – stands for picocuries per liter. A curie is a unit of radioactivity regarding the rate disintegration

**ppb** – 1 part per billion (equivalent to one penny in \$10,000,000).

**ppm** – 1 part per million (equivalent to one penny in \$10,000).

**Range** – Represents the end values recorded from the highest and lowest analytical results of a reported contaminant.

**Treatment Technique** – A required process intended to reduce the level of a contaminant in drinking water.

**Public Involvement**

Drinking water system information can be obtained by contacting the Naval Base Kitsap Public Affairs Office, at 360-627-4031.

## Consumer Confidence Report Information Provided to the Navy Data from Calendar Year 2019

We understand this is a stressful time for our community and for the households and businesses we serve. Please know that we are here for you and are committed to taking all steps necessary to maintain safe, reliable water service.

### You can continue normal use of tap water.

- The U.S. Environmental Protection Agency (EPA) recommends that Americans continue to use and drink tap water as usual.
- According to the U.S. Centers for Disease Control and Prevention (CDC), current treatment methods used by the City of Bremerton in water treatment plants are sufficient to disinfect water for contaminants, including COVID 19.

### We are prepared to keep safe water flowing.

- We are well-prepared to continue providing water service throughout this pandemic. We have staff and infrastructure in place to maintain safe water service around the clock to help keep families healthy, clean and hydrated.
- Given the importance of hygiene and sanitation to prevent the spread of COVID-19, we are postponing water service shutoffs until further notice.

### Please don't flush "flushable" items

Remember that your toilet should not be used as a trash can. Please do not treat other items like toilet paper. Please do not flush paper towels, "flushable" wipes, napkins, tampons, cotton balls, dental floss or other substances. Flushing nonbiodegradable items can result in backups and overflows of the sewer system.

### Source Water Information

The City of Bremerton's drinking water sources are surface water from the Union River and groundwater from production wells located in the Bremerton area. Bremerton owns and protects the 3,000 acre watershed surrounding the Union River supply. Access to the watershed is limited and only water supply and forestry management activities take place there. Groundwater wells are also safeguarded through wellhead protection efforts. All water facilities are monitored and patrolled. In 2017, the American Water Works Association recognized Bremerton with an Exemplary Source water protection Award.

### Bremerton's Water Needs Minimal Treatment

The City of Bremerton's water system is operated and maintained by experienced personnel certified by the state. The Washington State Department of Health has determined that Bremerton's source water in the Union River is of such good quality that the City is not required to install filtration as long as all water quality, operational, and watershed protection requirements are met. Bremerton consistently meets these high quality standards. Treatment of Bremerton's water currently consists of ultraviolet light and chlorine for disinfection and adjustment to increase pH to reduce corrosion of lead and copper from customer plumbing. Corrosion control has been in place since 1999.

### Required Source Water Quality Data:

Your drinking sources are regularly tested in accordance with all federal and state regulations. The City of Bremerton tests for inorganic and organic compounds. These results meet the health protective primary standards set by federal and state agencies. ***Not listed are the compounds that were tested for but were NOT detected.*** The amounts allowed in drinking water are so small they are measured in parts per million and parts per billion.

On September 21, 2019, the return of rainfall to the watershed resulted in suspended sediment (turbidity) in the Union River Reservoir above 1 NTU (a measure of turbidity). When source water turbidity exceeds 1 NTU, the City is required to collect two Fecal Coliform bacteria samples. One is collected at the source at the water intake facility, and one is collected where treated water enters the distribution system. The City collected the sample at the entry point to the distribution system, but neglected to collect the sample at the intake facility.

Fortunately, the results of the sample taken at the entry point to the distribution system was satisfactory (no fecal coliform bacteria detected), and the drinking water delivered to your tap met all state and federal water quality standards.

However, the City takes its responsibility as a water purveyor and steward of public health very seriously. The turbidity event sampling standard operating procedure was updated and all supervisors and operators received additional training to ensure that this does not happen again.

For more information, visit: [www.bremertonwa.gov/282/Drinking-Water-Quality-Report](http://www.bremertonwa.gov/282/Drinking-Water-Quality-Report)

Substances Detected						
Parameter	Highest Level Allowed EPA's MCL	Ideal Goals EPA's MCLG	Potential Sources	Highest Level Detected in 2019 to Determine Compliance	Range of Levels Detected in 2018	Meets Protective Health Standard
Regulated at the Surface Water Source						
Turbidity	Treatment Technique 5 NTU	N/A	Soil runoff	1.72 NTU	0.43 – 1.33 NTU	Yes
Sodium <small>Most recently sampled in 2012, next sample due after 2019.</small>	No Limit Set	N/A	Naturally-occurring	5.73 ppm	ND – 5.73 ppm	Yes
Regulated at the Groundwater Sources						
Sodium <small>Most recently sampled in 2012, next sample due after 2019.</small>	No Limit Set	N/A	Naturally-occurring	7.39 ppm	7.39 ppm	Yes

**Definitions:**

**EPA** is the United States Environmental Protection Agency.

**MCLG (Maximum Contaminant Level Goal)** is the level of a contaminant in drinking water below which no known or expected risk to health exists. MCLGs allow for a margin of safety.

**MCL (Maximum Contaminant Level)** is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**ND (Not Detected)** means the laboratory did not detect this parameter above the state reporting limit.

**NTU (Nephelometric Turbidity Unit)** is the measurement of water clarity. Monitoring turbidity is an indicator of water quality.

**ppb (part per billion)** is the same as a **ug/L (microgram per liter)** and equivalent to one penny in \$10,000,000.

**ppm (part per million)** is the same as **mg/L (milligram per liter)** and is equivalent to one penny in \$10,000.

**Treatment Technique** is a required process intended to reduce the level of a contaminant. Bremerton's surface supply is not used when turbidity increases above set points.

Submitted by:	Lisa Campbell, City of Bremerton Environmental Technician
Date:	3-24-2020
Submitted via email to:	<a href="mailto:Joshua.bass1@naw.mil">Joshua.bass1@naw.mil</a> <a href="mailto:scott.horwitz@naw.mil">scott.horwitz@naw.mil</a> <a href="mailto:Kenneth.eiford@navy.mil">Kenneth.eiford@navy.mil</a>

## Common Household Hazards

### *Chemical Spray Applicators*

The chemicals used on your lawn and garden can be toxic or fatal if ingested. These chemicals include pesticides, herbicides, and fertilizers. Even strong cleaning chemicals sprayed on cars, house siding, etc., may cause health problems if ingested.

### *Submerged Hoses*

Water held in pools, ponds or other vats open to the air and exposed to humans or animals may contain microbiological contaminants. Hoses submerged in buckets or containers can act as a conduit for contaminants under backflow conditions.

### *Underground Lawn Irrigation Systems*

Underground irrigation systems often have puddles of standing water around the ground-level sprinkler heads. The sprinkler heads **are not** designed to be drip-tight under backflow conditions. The puddles of water may contain microbiological contaminants, such as excrement from animals or chemical residue from fertilizer and herbicides sprayed on the lawn.



For further  
information  
contact your  
local water  
purveyor or the  
PNWS/AWWA  
Cross-Connection  
Control Committee  
through the  
PNWS office at  
(877) 767-2992  
or on the web at  
[www.pnws-awwa.org](http://www.pnws-awwa.org)

© 2003 R 06/03 [Brochure #4]

Help protect your  
**Drinking Water**  
from  
**Contamination**

## **Household Hazards**



American Water Works Association  
Pacific Northwest Section

## How Contamination Occurs

Water normally flows in one direction, from the public water system through the customer's cold or hot water plumbing to a sink tap or other plumbing fixture. The plumbing fixture is the end of the potable water system and the start of the waste disposal system.

Under certain conditions water can flow in the reverse direction. This is known as **backflow**. Backflow occurs when a backsiphonage or backpressure condition is created in a water line.

**Backsiphonage** may occur due to a loss of pressure in the water distribution system during a high withdrawal of water for fire protection, a water main or plumbing system break, or a shutdown of a water main or plumbing system for repair. A reduction of pressure below atmospheric pressure creates a vacuum in the piping. If a hose bib was open and the hose was submerged in a wading pool during these conditions, the non-potable water in the pool would be siphoned into the house's plumbing and back into the public water system.

**Backpressure** may be created when a source of pressure, such as a pump, creates a pressure greater than that supplied from the distribution system. If a pump supplied from a non-potable source, such as a landscape pond, was accidentally connected to the plumbing system, the non-potable water could be pumped into the potable water supply.

## How to Prevent Contamination of Your Drinking Water

Protect your drinking water by taking the following precautions:

### **Don't:**

- Submerge hoses in buckets, pools, tubs, sinks, ponds, etc.
- Use spray attachments without a backflow prevention device.
- Connect waste pipes from water softeners or other treatment systems to the sewer, submerged drain pipe, etc.
- Use a hose to unplug blocked toilets, sewers, etc.

### **Do:**


- ✓ Keep the ends of hoses clear of all possible contaminants.
- ✓ If not already equipped with an integral (built-in) vacuum breaker, buy and install hose bib type vacuum breakers on all threaded faucets around your home. These devices are inexpensive and are available at hardware stores and home improvement centers.
- ✓ Install an approved backflow prevention assembly on all underground lawn irrigation systems. Remember, a plumbing permit is required for the connection of an underground lawn irrigation system to your plumbing system.

## Hose Connection Vacuum Breaker

Hose connection vacuum breakers are specifically made for portable hoses attached to threaded faucets. Their purpose is to prevent the flow of contaminated water back into the drinking water. These devices screw directly to the faucet outlet. They can be used on a wide variety of installations, such as service sinks, hose faucets near a wading pool, laundry tub faucets, etc.

Some units are designed for manual draining for freezing conditions. Some are furnished with breakaway set screws as a tamper proof feature.

These device are not intended for operation under continuous pressure.



**Hose Connection Vacuum Breaker**

## Protection of the Water Purveyor's Distribution System

In general, the installation of plumbing in compliance with the plumbing code will provide adequate protection for your plumbing system from contamination.

However, the water purveyor may require (as a condition of service) the installation of a backflow prevention assembly on the water service to provide additional protection for the public water system. A backflow prevention assembly will normally be required where a single-family residence has special plumbing that increases the hazard above the normal level found in residential homes, or where a hazard survey cannot be completed.

To help determine if a backflow prevention assembly is required, the water purveyor may send residential customers a Cross Connection Control Survey Questionnaire. The water purveyor will evaluate the returned questionnaires to assess the risk of contamination to the public water system. Based on the results of the evaluation, the installation of backflow prevention assemblies may be required on services to some customers.