



DEPARTMENT OF THE NAVY

NAVAL STATION EVERETT  
2000 WEST MARINE VIEW DRIVE  
EVERETT, WA 98207-5001

IN REPLY REFER TO:

1700


N4

1 Aug 22

From: Commanding Officer, Naval Station Everett

Subj: DRINKING WATER TEST RESULTS AT NAVAL STATION EVERETT CHILD DEVELOPMENT CENTER

1. The Navy is committed to maintaining safe drinking water on its installations. As we previously communicated, Navy policy requires the lead content of drinking water fountains, coolers and outlets in priority areas such as Child Development Centers (CDCs) be tested. Testing at the CDC onboard Naval Station (NAVSTA) Everett was conducted on 25 June 2022. Lead in drinking water typically comes from the plumbing inside buildings including lead service lines, fittings, solder, water fountains/coolers, and water faucets.
2. I am pleased to report that all water intended for consumption, to include drinking water and water intended for cooking or washing, is at or below the Navy lead screening level of 15 parts per billion (ppb). Following Navy policy, 52 samples from various locations in the CDC, to include sinks used for washing, were taken and sent to a state-certified laboratory for analysis.
3. Copies of all water test results are posted at the front desk of the NAVSTA Everett CDC and are also available at <https://cnrnw.cnmc.navy.mil/installations/NS-Everett/operations-and-management/Environmental-support-and-Compliance/Drinking-water-Testing-for-Lead/>. To learn more about the Navy's lead in Priority Sampling Program visit <https://cnrnw.cnmc.navy.mil/Operations-and-Management/Environmental-Stewardship-and-Compliance/Water-Quality-Information/>. To learn more about lead in drinking water in schools and day care centers visit the following EPA website: <https://www.epa.gov/childcare/resources-about-drinking-water-child-care-providers>.
4. While lead in the drinking water at the CDC is below the Navy screening levels for schools and daycare centers, if you have any health related questions or concerns about lead exposure, you are encouraged to contact your health care provider.



J. M. MENZEL

Distribution:  
All CDC Patrons